

PLANNING SERVICES APPLICATION

9

CONSULTATION SHEET

APPLICANT:

Kirsop & Company,
11 Sandridge Park,
Porters Wood,
St. Albans, Hertfordshire
AL3 6PH

APPLICATION NO: PP/99/02572

HAT.

APPLICATION DATED: 13/12/1999

DATE ACKNOWLEDGED: 22 December 1999

APPLICATION COMPLETE: 22/12/1999

DATE TO BE DECIDED BY: 16/02/2000

SITE: 214 Earls Court Road, London, SW5 9QB

PROPOSAL: Existing retail use. Proposal includes new refrigeration units to rear elevation and roof structure over to protect from falling leaves.

ADDRESSES TO BE CONSULTED

- 1. Upper floors 214, 210, 212, 216, 218 Earls Ct Rd.
2.
3.
4. 2 Trebovir Rd.
5.
6.
7. 214 Earls Ct Rd = Flats 1-3.
8. 210/212 = shop
9. 216/218 = shop.
10.
11.
12. 216 = flat C.
13. 1st floor front 216-218 offices
14. 1st floor rear 216-218 offices
15.

Flats 1-53.
Sunnyhill Court
2-6 Trebovir Rd.
SW5 9LX

CONSULT STATUTORILY

- HBMC Listed Buildings
HBMC Setting of Buildings Grade I or II
HBMC Demolition in Conservation Area
Demolition Bodies
DoT Trunk Road - Increased traffic
DoT Westway etc.,
Neighbouring Local Authority
Strategic view authorities
Kensington Palace
Civil Aviation Authority (over 300')
Theatres Trust
National Rivers Authority
Thames Water
Crossrail
LRT/Chelsea-Hackney Line

ADVERTISE

- Effect on CA
Setting of Listed Building
Works to Listed Building
Departure from UDP
Demolition in CA
"Major Development"
Environmental Assessment
No Site Notice Required
Notice Required other reason
Police
L.P.A.C
British Waterways
Environmental Health
(jm in form)

30/12

22/12

DEVELOPMENT CONTROL

TECHNICAL INFORMATION



ADDRESS 214 Earls Court Road.

10

POLLING DISTRICT 4A PP992572

- | | | | |
|-----|--|--------|--|
| HB | Buildings of Architectural Interest | LSC | Local Shopping Centre |
| AMI | Areas of Metropolitan Importance | AI | Sites of Archeological Importance |
| MDO | Major Sites with Development Opportunities | SV | Designated View of St Paul's from Richmond |
| MOL | Metropolitan Open Land | SNCI | Sites of Nature Conservation Importance |
| SBA | Small Business Area | REG 7 | Restricted size and use of Estate Agent Boards |
| PSC | Principal Shopping Centre (Core or Non-core) | ART IV | Restrictions of Permitted Development Rights |

Conservation Area	HB	CPO	TPO	AMI	MDO	MOL	SBA	Unsuitable for Diplomatic use	PSC		LSC	AI	SV	SNCI	REG 7	ART IV
									C	N						
11D											✓				✓	

Within the line of Safeguarding of the proposed Chelsea/Hackney underground line

Within the line of Safeguarding of the proposed Eastwest/Crossrail underground line

Density	
Site Area	
Habitable rooms proposed	
Proposed Density	

Plot Ratio	
Site Area	
Zoned Ratio	
Floor Area proposed	
Proposed Plot Ratio	

Daylighting	Complies	
	Infringes	

Car Parking	Spaces required	
	Spaces proposed	

Notes:



MEMORANDUM

TO: FOR FILE USE ONLY

**From: EXECUTIVE DIRECTOR
PLANNING & CONSERVATION**

**My Ref: PP/99/02572/
Room No:**

CODE A1

Date: 22 December 1999

DEVELOPMENT AT:

214 Earls Court Road, London, SW5 9QB

DEVELOPMENT:

Existing retail use. Proposal includes new refrigeration units to rear elevation and roof structure over to protect from falling leaves.

The above development is to be advertised under:-

1. Section 73 of the Planning (Listed Buildings and Conservation Areas) Act 1990 (development affecting the character or appearance of a Conservation Area or adjoining Conservation Area)

M.J. French
Executive Director, Planning & Conservation

PLANNING AND CONSERVATION

THE TOWN HALL HORNTON STREET LONDON W8 7NX

Executive Director M J FRENCH FRICS TP MRTPI Cert TS

12

**THE ROYAL
BOROUGH OF**



**KENSINGTON
AND CHELSEA**

FILE COPY

0171-361-

Switchboard: 0171-937-5464

Extension:

Direct Line:

Facsimile: 0171-361-3463

Date: 30 December 1999

My reference:

Your reference:

Please ask for:

My Ref: DPS/DCSW/PP/99/02572/

Planning Information Office

Dear Sir/Madam,

TOWN AND COUNTRY PLANNING ACT 1990

Proposed development at: 214 Earls Court Road, London, SW5 9QB

Brief details of the proposed development are set out below. Members of the public may inspect copies of the application, the plans and any other documents submitted with it. The Council's Planning Services Committee, in considering the proposal, welcomes comments either for or against the scheme. Anyone who wishes to make representations about the application should write to the Council at the above address **within 21 days** of the date of this letter. Unfortunately, the Council does not have the resources to advise objectors of the Committee date, and you should telephone for further information.

Proposal for which permission is sought

Existing retail use. Proposal includes new refrigeration units to rear elevation and roof structure over to protect from falling leaves.

Applicant

**Kirsop & Company, 11 Sandridge Park, Porters Wood, St. Albans, Hertfordshire
AL3 6PH**

**The Planning Information Office Christmas opening hours are as follows:-Mon 20th -
Thurs 23rd Dec. 9.00-16.45. (Fri 24th Dec 9.00-13.00.) Wed 29th & Thur 30th Dec
9.00-13.00 then 14.00-16.30. The office will be closed on 27th, 28th & 31st Dec. & 3rd
Jan. Normal office hours resume on Tues. 4th Jan at 9.00.**

Yours faithfully,

M. J. FRENCH

Executive Director, Planning and Conservation

13

WHAT MATTERS CAN BE TAKEN INTO ACCOUNT

When dealing with a planning application the Council has to consider the policies of the Borough Plan known as the Unitary Development Plan, and any other material considerations. The most common of these include (not necessarily in order of importance):

- * The scale and appearance of the proposal and impact upon the surrounding area or adjoining neighbours;
- * Effect upon the character or appearance of a Conservation Area;
- * Effect upon the special historic interest of a Listed Building, or its setting;
- * Effect upon traffic, access, and parking;
- * Amenity issues such as loss of Sunlight or daylight, Overlooking and loss of privacy, Noise and disturbance resulting from a use, Hours of operation

WHAT MATTERS CANNOT BE TAKEN INTO ACCOUNT

Often people may wish to object on grounds that, unfortunately, **cannot** be taken into account because they are not controlled by Planning Legislation. These include (again not in any order of importance):

- * Loss of property value;
- * Private issues between neighbours such as land covenants, party walls, land and boundary disputes, damage to property;
- * Problems associated with construction such as noise, dust, or vehicles (If you experience these problems Environmental Services have some control and you should contact them direct)
- * Smells (Also covered by Environmental Services)
- * Competition between firms;
- * Structural and fire precaution concerns; (These are Building Control matters)

WHAT HAPPENS TO YOUR LETTER

Planning applications where objections have been received are presented to the Planning Services Committee which is made up of elected Ward Councillors. Planning Officers write a report to the Committee with a recommendation as to whether the application should be granted or refused. Letters received are summarised in the report, and copies can be seen by Councillors and members of the public including the applicant. The Councillors make the decisions and are not bound by the Planning Officer's recommendation. All meetings of the Committee are open to the public.

If you would like further information, about the application itself or when it is likely to be decided, please contact the Planning Department on the telephone number overleaf.

WHERE TO SEE THE PLANS

Details of the application can be seen at the **Planning Information Office, 3rd floor, Town Hall, Hornton Street W.8.** It is open from 9am to 4.45pm Mondays to Thursdays (4pm Fridays). A Planning Officer will always be there to assist you.

In addition, copies of applications in the **Chelsea Area (SW1, SW3, SW10)** can be seen at **The Reference Library, Chelsea Old Town Hall, Kings Road SW3 (0171-361 4158)**, for the **Central Area (W8, W14, SW5, SW7)** can be viewed in the **Central Library, Town Hall, Hornton Street, W.8.** and applications for districts **W10, W11 and W2** in the **North** of the Borough can be seen at **The Information Centre, North Kensington Library, 108 Ladbroke Grove, London W11** (under the Westway near Ladbroke Grove Station **0171-727-6583**). Please telephone to check the opening times of these offices.

If you are a registered disabled person, it may be possible for an Officer to come to your home with the plans. Please contact the Planning Department and ask to speak to the Case Officer for the application.

PLEASE QUOTE THE APPLICATION REFERENCE NUMBER ON YOUR REPLY

14

THE ROYAL
BOROUGH OF

NOTICE OF A PLANNING APPLICATION



**KENSINGTON
AND CHELSEA**

TOWN AND COUNTRY PLANNING ACT 1990
PLANNING (LISTED BUILDINGS AND CONSERVATION AREAS) ACT 1990

Notice is hereby given the Royal Borough of Kensington and Chelsea Council have received an application:

- (a) for development of land in or adjacent to a Conservation Area.

Details are set out below.

Members of the public may inspect copies of the application, the plans and other documents submitted with it at:

NOTICE The Planning Information Office, 3rd floor, The Town Hall, Hornton Street, W8 7NX between the hours of 9.15 and 4.45 Mondays to Thursdays and 9.15 to 4.30 Fridays;

For applications in the Chelsea area: The Reference Library, Chelsea Old Town Hall, Tel. 0171-361-4158.

For postal areas W10, W11 and W2: The 1st floor, North Kensington Library, 108 Ladbroke Grove, W11, Tel. 0171-727-6583.

Anyone who wishes to make representations about this application should write to the Executive Director of Planning and Conservation at the Town Hall (Dept. 705) within 21 days of the date of this notice.

SCHEDULE

Reference: PP/99/02572/

Date: 31/12/1999

214 Earls Court Road, London, SW5 9QB

Existing retail use. Proposal includes new refrigeration units to rear elevation and roof structure over to protect from falling leaves.

APPLICANT Kirsop & Company,

Lamp PO 8V
35/12

INFORMATION REQUEST FORM

Planning Services to Environmental Health

*ten
Hooper*

To: Paul Morse - Director of Environmental Health

Address/Issue
214 East Coast Road, SWS

Planning Reference No.: PP/99/2572

Planning Case Officer: HELEN HANRED

Summary of Proposal:
Policy Issue/Subject of Advice

new all units - real electric
15

(key Features)(Uses,Scale etc.)(Main Issues/Problems).

Schedule of Attachments:	Schedule of Key Dates:
Specifications: <input type="text" value="1 schedule = units considered"/>	1. Case initiated/Application received: <input type="text" value="2 2 1 2 9 9"/>
Drawings: <input type="text" value="9144/001, 002, 100 etc."/>	4. Information required by: <input type="text" value="2 5 0 1 0 0"/>
Supporting Info: <input type="text"/>	2. Sent by Planning Services: <input type="text" value="1 1 0 1 0 0"/>
Draft Text etc.: <input type="text"/>	5. Returned by Environmental Health: <input type="text"/>
	3. Entered on EHIS: <input type="text" value="1 2 0 1 0 0"/>

Purpose/Status of Request:

<input checked="" type="checkbox"/> Planning Application	<input type="checkbox"/> Planning Appeal	<input type="checkbox"/> Planning Brief
<input type="checkbox"/> Planning Issues paper	<input type="checkbox"/> Planning Guidance	<input type="checkbox"/> UDP Consultation
<input type="checkbox"/> Impact Assessment	<input type="checkbox"/> General Advice	<input type="checkbox"/> Other

Nature of Request in brief:
are the proposed units acceptable in terms of noise output?
By how much could they increase background noise levels?

Previous Planning History:

Need for telephone discussion of background

Essentials of relevant UDP or other Policy:

Need for telephone discussion of background

Specific Issues for Environmental Health Comment

<input type="checkbox"/> Food	<input type="checkbox"/> Health and Safety	<input type="checkbox"/> HMO's	<input type="checkbox"/> Other
<input checked="" type="checkbox"/> Noise and Nuisance	<input type="checkbox"/> Contaminated Land	<input type="checkbox"/> Air Quality	

E.H. Response: (Continue on reverse if necessary) **EHIS Reference No.:** 706702/00

see attached memo.

E.H. Case officer(s) and telephone number(s): ROBERT LOCKWOOD x 5149

TO ENVIRONMENTAL HEALTH TO PLANNING SERVICES TO ENVIRONMENTAL HEALTH TO PLANNING SERVICES TO ENVIRONMENTAL HEALTH TO PLANNING SERVICES TO...

FILE

ENVIRONMENTAL SERVICES
INTERNAL MEMORANDUM

TO: Helen Homard, Planning Officer ROOM NO:
CC:
FROM: Robert Lockwood ROOM NO:
TELEPHONE 0171-341 5149 CONNECT: DEHRJL
DATE: 26 January 2000 REF: PP/99/2572
SUBJECT: 214 Earls Court Road

16

With regards to the above planning application I have the following comments to make:

Having visited the site and read the technical literature provided, I do not foresee that the installation of 3 No. ZR28 Condenser Units will amount to any significant rise in the background noise level at the nearest residential premises. I the consider the following standard planning condition should be satisfactory and achievable.

The lowest background noise level ($L_{A90,T}$) at 1 metre from the facade of the nearest occupied premises, during the period of operation of the units, should not be increased by more than 2dB.

THE ROYAL BOROUGH OF KENSINGTON AND CHELSEA
MEMORANDUM - SECTION 101 - LOCAL GOVERNMENT ACT, 1972

17

ac
DPI

To: Chief Administrative Officer (Planning)
From: The Executive Director, Planning & Conservation

Date: 31 January 2000
Our Ref: PP/99/02572

mns
51
112

Application Date: 13/12/1999 Complete Date: 22/12/1999 ~~Revised Date:~~
Agent: Kirsop & Company, 11 Sandridge Park, Porters Wood, St. Albans,
Hertfordshire AL3 6PH
Address: 214 Earl's Court Road, London, SW5 9QB
Kensington

This application is for a class of development to be determined under powers delegated to me by the Council on 21st July, 1976, and/or by the Town Planning Committee 6th November, 1979, and/or by the Town Planning Committee on 18th March 1986, 23rd May 1988 and 8th January 1990 and is not such as I wish to refer to the Planning Application Committee. No relevant planning objections have been received.

- Class (i) - 8th Schedule development
- Class (ii) - shop fronts
- Class (iii) - conversion from non s/c dwellings etc
- Class (iv) - amendments as required by T.P. Committee
- Class (v) - above classes after D.P. Committee agree
- Class (vi) - Listed building consent for above Classes.
- Class (vii) - approval of facing materials
- Class (viii) - grant of planning permission for a change from one kind of non-residential use except from one kind of non-residential use except where this would involve the loss of shop use
- Class (ix) - grant permission licence or no objection under Sections 73, 74, 138, 143, 152, 153, 177 & 180 of the Highways Act
- Class (x) - Crossover under S. 108 of the Highways Act 1980

DELEGATED APPROVAL
07 FEB 2000

Consent under T&CP Control of Advertisement Regulations 1984-90; incl. refusal of consent for Reg. 15 applications.

DESCRIPTION OF PROPOSED DEVELOPMENT

Installation of three refrigeration units to rear elevation and roof structure ^{above} ~~over to~~ protect from falling leaves.

RECOMMENDED DECISION Grant planning permission *conditionally*
RBK&C drawing(s) No. PP/99/2572
9144/001A and 002A and Copeland specifications (rec'd 20/12/99)

I hereby determine and ~~grant~~ ^{9144/} refuse this application (subject to ~~HBMG Direction/Historic Building~~ ~~authorisation~~) under the powers delegated to me by the Council, subject to the condition(s) indicated below imposed for the reason(s) appearing thereunder, or for the reasons stated.

Exec. Director, Planning and Conservation Head of Development Control Area Planning Officer

Johns 4.2.2000

18

CONDITIONS AND REASONS FOR THEIR IMPOSITION

1 The development hereby permitted shall be begun before the expiration of five years from the date of this permission. (C001)
Reason As required by Section 91 of the Town and Country Planning Act 1990, to avoid the accumulation of unexercised Planning Permissions. (R001)

2 The development hereby permitted shall be carried out exactly and only in accordance with the drawings and other particulars forming part of the permission and there shall be no variation therefrom without the prior written approval of the Local Planning Authority. (C068)
Reason - The details are considered to be material to the acceptability of the proposals, and for safeguarding the amenity of the area. (R068)

3 The lowest background noise level (L A90,T) at 1 metre from the facade of the nearest occupied premises during the period of operation of the units, should not be increased by more than 2dB. C57A

Reason - To safeguard the amenities of surrounding residents.

INFORMATIVES

- 4 Details of the materials to be used for the proposed canopy shall be submitted to and approved in writing by the Executive Director Planning & Conservation before any work commences on site. R71
- 1 I09
 - 2 I10
 - 3 I21
 - 4 I30
 - 5 I31
 - 6 I37

DELEGATED REPORT

Address

214 East's Court Road
Kensington
London
SW5

Reference PP/99/02572

Conservation Area 110

Listed Building Yes/No

19

Type of Application

Planning Permission/Approval of Materials/Variation of Condition/Listed Building Consent/Conservation Area Consent

Type of Development

Residential Extension

Roof

Rear

Storeys _____

Side

Front

Garden

Residential Alterations

Residential Conversion

From _____

To _____

Other 3 x refrigeration units 165 elevators

Shopfront

Non-Residential Extension

Listed Building Demolition

whole part

Listed Building Alterations

Unlisted Building - Demolition

whole part

continued

D451(a)

Objections (withdrawn etc.) (incl. internal - Design, Policy, Transportation etc.)

Who none

Overcome by Amendment/Withdrawn/Not Relevant/Other _____

20

Existing

Retail

Issues/Policy/Precedent/Conditions/Third Schedule

see attached report

Standards

satisfactory

- Light
- Privacy
- Room Sizes
- Parking
- Trees

HBMC Direction/Obs.

- Obs. Rec'd
- Direction Rec'd
- Consultation Expired

GRANT/APPROVE

subject to conditions

Informatives

Report by HTT

Date 31/1/00

Agreed

WWS
4/2/2000

1.0 Planning Considerations

1.1 The main considerations in this case relate to the effect of the proposal on the appearance of the building itself and on the character and appearance of the surrounding area. The effect of the proposal on the amenities of surrounding residents should also be considered.

1.2 The relevant planning Policies are contained in the "Conservation and Development" Chapter of the Unitary Development Plan. Policies CD44, and CD34 are of particular relevance to this application.

1.3 This application seeks to install three new refrigeration units at rear ground floor level. The proposed units are to be positioned below the two existing air conditioning units located on the rear elevation at ground floor level. There is a small open yard to the rear surrounded to the West by a high brick wall that effectively screens the ground floor elevation from views from surrounding properties. Given the proposed location of the units it is not considered that the proposal would result in harm to the appearance of the building or the surrounding area.

1.4 With regard to the effect of the proposal on the amenities of surrounding residents, the Council's Environmental Health Officer considers that the proposed units would not result in a significant rise in the background noise level at the nearest residential property.

1.5 It is therefore considered that the proposal would be consistent with the aims of Policies CD44, and CD34 as contained in the Unitary Development Plan.

i.e. Details of canopy should be subject to a condition to ensure appropriate materials are used.

2.0 Public Consultation

2.1 61 letters of notification were sent to properties in the Earl's Court Road and Trebovir Road.

2.2 No objections have been received.

**M.J. FRENCH
EXECUTIVE DIRECTOR, PLANNING AND CONSERVATION**

List of Background Papers:

The contents of file PP/99/02572 save for exempt or confidential information in accordance with the Local Government (Access to Information) Act 1985.

Report Prepared By:

Report Approved By: /LAWJ *LAWJ*

Date Report Approved: *4/2/2000*

112




PP992572

22

DELEGATED
APPROVAL
07 FEB 2000

PP992572



R.B.K. & C.
TOWN PLANNING
20 DEC 1999
RECEIVED

Copeland
Impact Scroll

23

Copeland

Technical Data

Technische Daten

Données Techniques



Condensing Unit air-cooled	Receiver Volume (Charge max.)	Fan	Width	Depth	Height	Base Mounting	Suction Line ³⁾	Liquid Line ³⁾	Air Flow Condenser	Weight net/gross	Housing (optional)			
Verflüssigungssatz luftgekühlt	Sammler Volumen (Füllmenge max.)	Lüfter	Breite	Tiefe	Höhe	Befestigungs- löcher	Saugleitungs- anschluß ³⁾	Flüssigkeits- anschluß ³⁾	Luftmenge	Gewicht netto/brutto	Gehäuse (optional)			
Groupe frigorifique refroidi par air	Réservoir (Charge max.) Standard	Vent.	Larg.	Profond.	Haut.	Trous de fixation	Tube Aspiration ³⁾	Tube Liquide ³⁾	Condens. débit air	Poids net/brut	Capotage (optionnel)			
Index: Page 7 / Seite 7	l (kg) ⁴⁾	no	B mm	T mm	H mm	b x t mm	Ø mm	Ø L* (mm)	Ø L* (mm)	m ³ /s	kg			
SAN1-D8-ZR22K	3,7	1	560	570	446	530x330	11	3/4	18	1/2	12	0,44	48/58	B/D
SAN1-D8-ZR28K	3,7	1	560	570	446	530x330	11	3/4	18	1/2	12	0,44	49/59	B/D
SAN1-H8-ZR34K	7,5	1	735	680	533	700x370	14	3/4	18	1/2	12	0,51	60/75	H
SAN1-H8-ZR40K	7,5	1	735	680	533	700x370	14	3/4	18	1/2	12	0,91	61/76	H
SAN1-H8-ZR49K	7,5	1	735	680	535	700x370	14	7/8	22	1/2	12	0,91	73/88	H
SAN1-H9-ZR61K	7,5	1	735	680	535	700x370	14	7/8	22	1/2	12	0,84	76/91	H
SAN2-P8-ZR72K	7,5	2	1130	680	633	1095x350	14	7/8	22	1/2	12	1,05	105/145	R/CR
SAN2-R7-ZR81K	7,5	2	1130	680	633	1095x350	14	7/8	22	1/2	12	1,85	106/146	R/CR
SAN2-R7-ZR90K	7,5	2	1130	680	633	1095x350	14	1 1/8	28	1/2	12	1,85	156/196	R/CR
SAN2-V9-ZR12M	14,0	2	1330	820	835	1295x475	14	1 3/8	28	3/4	18	1,95	194/274	V
SAN2-V9-ZR16M	14,0	2	1330	820	835	1295x475	14	1 3/8	28	3/4	18	1,95	200/280	V

Dual-Fan Unit

Verflüssigungssatz mit zwei Lüftern

Groupe frigorifique bi-ventilateur

DELEGATED
APPROVAL
07 FEB 2000



R.B.K. & C.
TOWN PLANNING
20 DEC 1999
RECEIVED

24

Electrical Data

Elektrische Daten

Caractéristiques Electriques


Condensing Unit air-cooled Verflüssigungssatz luftgekühlt Groupe frigorifique refroidi par air	Max. Operating Current (A) motor version and fan models s.p.7			max. Betriebsstrom (A) Motorversion und Ventilatormodelle s.S.7			Intensité max. de fonction. (A) Version du moteur et modèles de ventilateur v.p.7			
	Compressor / Verdichter / Compresseur Fan / Ventilator / Ventilateur						Unit / Verflüssigungssatz / Groupe frig.			
	PFJ	TF5	TFD / *TWD	Mod.	PFJ	TF5	TFD / TWD	PFJ	TF5	TFD / *TWD
SAN1-D8-ZR22K	10,7	-	3,70	120	0,63	-	0,32	11,3	-	4,02
SAN1-D8-ZR28K	13,6	-	4,80	120	0,63	-	0,32	14,2	-	5,12
SAN1-H8-ZR34K	15,3	-	5,70	270	1,30	-	0,65	16,6	-	6,35
SAN1-H8-ZR40K	18,7	-	6,60	270	1,30	-	0,65	20,0	-	7,25
SAN1-H8-ZR49K	-	15,5	7,90	270	-	1,10	0,65	-	16,6	8,55
SAN1-H9-ZR61K	-	19,9	10,0	270	-	1,10	0,65	-	21,0	10,7
SAN2-P8-ZR72K	-	22,7	11,4	120	-	2 x 0,55	2 x 0,32	-	24,9	12,7
SAN2-R7-ZR81K	-	25,2	13,3	270	-	2 x 1,10	2 x 0,65	-	27,4	14,6
SAN2-R7-ZR90K	-	-	* 14,6	270	-	-	2 x 0,65	-	-	* 15,9
SAN2-V9-ZR12M	-	-	* 19,2	270	-	-	2 x 0,65	-	-	* 20,5
SAN2-V9-ZR16M	-	-	* 25,6	270	-	-	2 x 0,65	-	-	* 26,9

**DELEGATED
APPROVAL**
 07 FEB 2000

Single-Fan Unit

Verflüssigungssatz mit einem Lüfter

Groupe frigorifique mono-ventilateur



R.B.K.&C.
TOWN PLANNING
 20 DEC 1999
RECEIVED



25

Provisional A-Weighted Sound Pressure Levels Aircooled Units

SAN1-D7-ZR22K	67.0 dBa
SAN1-D7-ZR28K	67.0 dBa
SAN1-H7-ZR34K	68.0 dBa
SAN1-H7-ZR40K	68.0 dBa
SAN1-H8-ZR49K	72.0 dBa
SAN1-H9-ZR61K	73.0 dBa
SAN2-R4-ZR72K	75.0 dBa
SAN2-R7-ZR90K	75.5 dBa
SAN2-V9-ZR12M	75.0 dBa
SAN2-V9-ZR16M	75.0 dBa

DELETED
APPROVAL
07 FEB 2000

The above values are provisional, calculated and not from test results.

Values are at 1 metre distance with general tolerance +/- 3 dBa

If the ALCO FV31 fan speed control is fitted a further reduction of 6 dBa may be obtained given varying ambient conditions.

R.B.K.&C.
TOWN PLANNING
20 DEC 1999
RECEIVED